

CONSUMER CONFIDENCE REPORT

PWSID: 1720006

City of Henderson 2016 Drinking Water Report

The City of Henderson is issuing the results of monitoring done on its drinking water for the period from January 1 to December 31, 2016. The purpose of this report is to advance consumers' understanding of drinking water and heighten awareness of the need to protect precious water resources.

Source of Water

The City of Henderson provides drinking water to its residents from a groundwater source: two wells ranging from 706 to 900 feet deep, that draw water from the Mt. Simon and Jordan-Mt.Simon aquifers.

The Minnesota Department of Health has made a determination as to how vulnerable our systems' source(s) of water may be to future contamination incidents. If you wish to obtain the entire source water assessment regarding your drinking water, please call 651-201-4700 or 1-800-818-9318 (and press 5) during normal business hours. Also, you can view it on line at www.health.state.mn.us/divs/eh/water/swp/swa.

Call James Kroehler 507-248-3234 if you have questions about the City of Henderson drinking water or would like information about opportunities for public participation in decisions that may affect the quality of the water.

Results of Monitoring

No contaminants were detected at levels that violated federal drinking water standards. However, some contaminants were detected in trace amounts that were below legal limits. The table that follows shows the contaminants that were detected in trace amounts last year.

Key to abbreviations:

MCLG—Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL—Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL—Maximum Residual Disinfectant Level.

MRDLG—Maximum Residual Disinfectant Level Goal.

AL—Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

90th Percentile Level—This is the value obtained after disregarding 10 percent of the samples taken that had the highest levels. (For example, in a situation in which 10 samples were taken, the 90th percentile level is determined by disregarding the highest result, which represents 10 percent of the samples.) Note: In situations in which only 5 samples are taken, the average of the two with the highest levels is taken to determine the 90th percentile level.

pCi/l—PicoCuries per liter (a measure of radioactivity).

CONSUMER CONFIDENCE REPORT

PWSID: 1720006

ppm—Parts per million, which can also be expressed as milligrams per liter (mg/l).

ppb—Parts per billion, which can also be expressed as micrograms per liter (µg/l).

N/A—Not Applicable (does not apply).

Contaminant (units)	MCLG	MCL	Level Found		Typical Source of Contaminant
			Range (2016)	Average /Result*	
Alpha Emitters (pCi/l)	0	15.4	N/A	6.4	Erosion of natural deposits.
Arsenic (ppb)	0	10	N/A	1.67	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium (ppm)	2	2	N/A	.06	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Combined Radium (pCi/l)	0	5.4	N/A	4.2	Erosion of natural deposits.
Fluoride (ppm) **	4	4	.66-.76	.72	State of Minnesota requires all municipal water systems to add fluoride to the drinking water to promote strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories.
Haloacetic Acids (HAA5) (ppb)	0	60	N/A	1.6	By-product of drinking water disinfection.
TTHM (Total trihalomethanes) (ppb)	0	80	N/A	1	By-product of drinking water disinfection.

*This is the value used to determine compliance with federal standards. It sometimes is the highest value detected and sometimes is an average of all the detected values. If it is an average, it may contain sampling results from the previous year.

Contaminant (units)	MRDLG	MRDL	****	*****	Typical Source of Contaminant
Chlorine (ppm)	4	4	.62-.95	.75	Water additive used to control microbes.

****Highest and Lowest Monthly Average.

*****Highest Quarterly Average.

Contaminant (units)	MCLG	AL	90% Level	# sites over AL	Typical Source of Contaminant
Copper (ppm)	1.3	1.3	.45	0 out of 10	Corrosion of household plumbing systems; Erosion of natural deposits.

CONSUMER CONFIDENCE REPORT

PWSID: 1720006

City of Henderson 2016 Drinking Water Report

The City of Henderson is issuing the results of monitoring done on its drinking water for the period from January 1 to December 31, 2016. The purpose of this report is to advance consumers' understanding of drinking water and heighten awareness of the need to protect precious water resources.

Source of Water

The City of Henderson provides drinking water to its residents from a groundwater source: two wells ranging from 706 to 900 feet deep, that draw water from the Mt. Simon and Jordan-Mt.Simon aquifers.

The Minnesota Department of Health has made a determination as to how vulnerable our systems' source(s) of water may be to future contamination incidents. If you wish to obtain the entire source water assessment regarding your drinking water, please call 651-201-4700 or 1-800-818-9318 (and press 5) during normal business hours. Also, you can view it on line at www.health.state.mn.us/divs/eh/water/swp/swa.

Call [James Kroehler 507-248-3234](tel:507-248-3234) if you have questions about the City of Henderson drinking water or would like information about opportunities for public participation in decisions that may affect the quality of the water.

Results of Monitoring

No contaminants were detected at levels that violated federal drinking water standards. However, some contaminants were detected in trace amounts that were below legal limits. The table that follows shows the contaminants that were detected in trace amounts last year.

Key to abbreviations:

MCLG—Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL—Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL—Maximum Residual Disinfectant Level.

MRDLG—Maximum Residual Disinfectant Level Goal.

AL—Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

90th Percentile Level—This is the value obtained after disregarding 10 percent of the samples taken that had the highest levels. (For example, in a situation in which 10 samples were taken, the 90th percentile level is determined by disregarding the highest result, which represents 10 percent of the samples.) Note: In situations in which only 5 samples are taken, the average of the two with the highest levels is taken to determine the 90th percentile level.

pCi/l—PicoCuries per liter (a measure of radioactivity).

CONSUMER CONFIDENCE REPORT

PWSID: 1720006

ppm—Parts per million, which can also be expressed as milligrams per liter (mg/l).

ppb—Parts per billion, which can also be expressed as micrograms per liter (µg/l).

N/A—Not Applicable (does not apply).

Contaminant (units)	MCLG	MCL	Level Found		Typical Source of Contaminant
			Range (2016)	Average /Result*	
Alpha Emitters (pCi/l)	0	15.4	N/A	6.4	Erosion of natural deposits.
Arsenic (ppb)	0	10	N/A	1.67	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium (ppm)	2	2	N/A	.06	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Combined Radium (pCi/l)	0	5.4	N/A	4.2	Erosion of natural deposits.
Fluoride (ppm)	4	4	.66-.76	.72	State of Minnesota requires all municipal water systems to add fluoride to the drinking water to promote strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories.
Haloacetic Acids (HAA5) (ppb)	0	60	N/A	1.6	By-product of drinking water disinfection.
TTHM (Total trihalomethanes) (ppb)	0	80	N/A	1	By-product of drinking water disinfection.

*This is the value used to determine compliance with federal standards. It sometimes is the highest value detected and sometimes is an average of all the detected values. If it is an average, it may contain sampling results from the previous year.

Contaminant (units)	MRDLG	MRDL	****	*****	Typical Source of Contaminant
Chlorine (ppm)	4	4	.62-.95	.75	Water additive used to control microbes.

****Highest and Lowest Monthly Average.

*****Highest Quarterly Average.

Contaminant (units)	MCLG	AL	90% Level	# sites over AL	Typical Source of Contaminant
Copper (ppm)	1.3	1.3	.45	0 out of 10	Corrosion of household plumbing systems; Erosion of natural deposits.