



MINNESOTA DEPARTMENT OF HEALTH
SECTION OF DRINKING WATER PROTECTION
Report of Analytical Results



625 Robert St. N. St. Paul MN 55155
P.O. Box 64975 St. Paul MN 55164 - 0975

Final Report - Client Copy

The following are the results of your annual nitrate sample analysis required for compliance with federal rule, CFR 141.23.

System Name: **Henderson**

PWSID: **1720006**

Date Collected: 6/12/2023

Sample #: 23F1046-01

Date Received: 6/12/2023

Sample Point ID: E01

Date Analyzed: 6/13/2023

Collected by: James Kroehler

Sampling Point: Well #1 Entry Point

ANALYSIS RESULTS:

<u>Contaminant</u>	<u>Result</u>	<u>Maximum Contaminant Level (MCL)</u>	<u>Units</u>
Nitrate + Nitrite Nitrogen, Total	<.05	10.4	mg/L

Date Collected: 6/12/2023

Sample #: 23F1046-02

Date Received: 6/12/2023

Sample Point ID: E03

Date Analyzed: 6/13/2023

Collected by: James Kroehler

Sampling Point: Well #2 Entry Point

ANALYSIS RESULTS:

<u>Contaminant</u>	<u>Result</u>	<u>Maximum Contaminant Level (MCL)</u>	<u>Units</u>
Nitrate + Nitrite Nitrogen, Total	<.05	10.4	mg/L

COMMENTS:

The result(s) above show that your system is in compliance with maximum contaminant levels set by the state and federal Safe Drinking Water Rules for the contaminant analyzed. These results must be kept in your files for a minimum of ten (10) years.

If you have any questions concerning these results, call Cindy Swanson at 651/201-4656.